

Recordall® II Registers on Recordall Turbo Series Meters	Correction Factors	Application Brief
---	---------------------------	------------------------------

Correction factor for wrong meter and register combinations. To obtain correct usage or registration, multiply reading on wrong register by the correction factor indicated in appropriate box.

RECORDALL® TURBO SERIES*:

RECORDALL TURBO SERIES METER MODEL

**RECORDALL II LOCAL REGISTER AND
RECORDALL TRANSMITTER REGISTER (RTR®)**

	1 1/2" T-160	2" T-200	3" T-450	4" T-1000	6" T-2000	8" T-3500	10" T-5500	12" T-6200
2"	.9614	.9614	.9243	.8872	9.8425	9.7550	7.4597	11.4765
3"	.9511	.9511	.9145	.8778	9.7371	9.6510	7.3801	11.3541
4"	.6306	.6306	.6063	.5820	6.4558	6.3987	4.8932	7.5279
6"	.1088	.1088	.1046	.1004	1.1146	1.1044	.8445	1.2993
8"	.0716	.0716	.0689	.0661	.7335	.7268	.5558	.8551
10"	.0220	.0220	.0211	.0203	.2253	.2232	.1707	.2626
12"	.0174	.0174	.0167	.0161	.1783	.1767	.1351	.2079
16"	.0101	.0101	.0097	.0093	.1036	.1027	.0785	.1208
20"	.0059	.0059	.0056	.0054	.0601	.0596	.04554	.0701

These correction factors apply for consistent units of measure (gallons desired and gallons on the incorrect register).

RTS-E-06

Recordall®, RTR®, and ACCESSplus® are registered trademarks of Badger Meter, Inc.

12-01



Please see our website at
www.badgermeter.com
for specific contacts.

Due to continuous research, product improvements and enhancements, Badger Meter reserves the right to change product or system specifications without notice, except to the extent an outstanding bid obligation exists.



BadgerMeter, Inc.
P.O. Box 245036, Milwaukee, WI 53224-9536
(800) 876-3837 / Fax: (888) 371-5982
www.badgermeter.com