

Recordall® Turbo Series	Correction Factors	Application Brief
------------------------------------	---------------------------	------------------------------

Correction factor for wrong meter and register combinations. To obtain correct usage or registration, multiply reading on wrong register by the correction factor indicated in appropriate box.

RECORDALL® TURBO SERIES* (Including Integral Strainer Models):

RECORDALL TURBO SERIES METER MODEL

**RECORDALL TURBO SERIES LOCAL REGISTER AND
RECORDALL TRANSMITTER REGISTER (RTR®) or
ABSOLUTE DIGITAL ENCODER (ADE®)**

	1 1/2" T-160	2" T-200	3" T-450	4" T-1000	6" T-2000	8" T-3500	10" T-5500	12" T-6200
1 1/2"	1.00	1.00	.9615	.9229	10.2409	10.1474	7.7598	11.9381
2"	1.00	1.00	.9615	.9229	10.2409	10.1474	7.7598	11.9381
3"	1.0400	1.0400	1.00	.9599	10.6508	10.5536	8.0704	12.4160
4"	1.0835	1.0835	1.0418	1.00	11.0958	10.9946	8.4076	12.9348
6"	.0976	.0976	.0939	.0901	1.00	.9909	.7577	1.1657
8"	.0985	.0985	.0948	.0910	1.0092	1.00	.7647	1.1765
10"	.1289	.1289	.1239	.1189	1.3198	1.3078	1.00	1.5385
12"	.0838	.0838	.0805	.0773	.8579	.8500	.6500	1.00

These correction factors apply for consistent units of measure (gallons desired and gallons on the incorrect register).

RTS-E-05

2-08

Recordall®, RTR®, and ACCESSplus® are registered trademarks of Badger Meter, Inc.



Please see our website at
www.badgermeter.com
for specific contacts.

Due to continuous research, product improvements and enhancements, Badger Meter reserves the right to change product or system specifications without notice, except to the extent an outstanding contractual obligation exists.



BadgerMeter, Inc.
P.O. Box 245036, Milwaukee, WI 53224-9536
(800) 876-3837 / Fax: (888) 371-5982
www.badgermeter.com