

Recordall® Turbo Series Registers on Recordall II Turbo Meters	Correction Factors	Application Brief
---	---------------------------	--------------------------

Correction factor for wrong meter and register combinations. To obtain correct usage or registration, multiply reading on wrong register by the correction factor indicated in appropriate box.

RECORDALL® TURBO SERIES*:

RECORDALL II METER MODEL

RECORDALL TURBO SERIES LOCAL REGISTER AND RECORDALL TRANSMITTER REGISTER (RTR®)

	2"	3"	4"	6"	8"	10"	12"	16"	20"
1 1/2"	1.0402	1.0514	1.5858	9.1883	13.9609	45.4636	57.4278	98.8528	170.3754
2"	1.0402	1.0514	1.5858	9.1883	13.9609	45.4636	57.4278	98.8528	170.3754
3"	1.0819	1.0935	1.6493	9.5561	14.5197	47.2833	59.7264	102.8095	177.1949
4"	1.1271	1.1392	1.7182	9.9554	15.1265	49.2592	62.2221	107.1055	184.5993
6"	.1016	.1027	.1549	.8972	1.3633	4.4394	5.6078	9.6528	16.6368
8"	.1025	.1036	.1563	.9055	1.3758	4.4803	5.6593	9.7417	16.7900
10"	.1341	.1355	.2044	1.1841	1.7991	5.8589	7.4007	12.7391	21.9562
12"	.0871	.0881	.1328	.7697	1.1694	3.8083	4.8104	8.2804	14.2715

These correction factors apply for consistent units of measure (gallons desired and gallons on the incorrect register).

RTS-E-07

Recordall®, RTR®, and ACCESSplus® are registered trademarks of Badger Meter, Inc.

12-01



Please see our website at
www.badgermeter.com
for specific contacts.

Due to continuous research, product improvements and enhancements, Badger Meter reserves the right to change product or system specifications without notice, except to the extent an outstanding bid obligation exists.



BadgerMeter, Inc.
P.O. Box 245036, Milwaukee, WI 53224-9536
(800) 876-3837 / Fax: (888) 371-5982
www.badgermeter.com